

ERRATA

FOR THE LOCAL AMENDMENTS TO THE 2007 CALIFORNIA FIRE CODE

(California Code of Regulations, Title 24, Part 9)

October 29, 2007

(Note: Items shown underlined denote the errata item that was revised).

SDMC Chapter 5 Article 5 Division 6

- **§55.0503**

Chapter 5, Section 503.2.1 (Delete proposed changes to the model code language)

503.2.1 Dimensions. Fire apparatus access roads shall have an unobstructed width of not less than 20 26 feet (6096 7924.8 mm), except for approved security not less than 13 feet 6 inches (4115mm).

Reason: Withdrawn by proponent. The proposed amendment to Section 503.2.1 increased the width of all fire access roads from 20 feet to 26 feet. It was not the proponents' original intent to increase fire apparatus access road width in all circumstances. Rather, the proposed change was meant to codify, in part, SDFD Policy #A-00-1 "Fire Access Roadways" which requires increased width only under certain circumstances. Additionally, CFC Section 503.2.2 gives the fire code official the authority to increase minimum access widths where they are inadequate for fire or rescue operations. The existing Fire Access Roadway policy would be utilized under this section to provide guidance.